



## **ADDENDUM NO. 1 BID OPPORTUNITY NO. 232-2004**

**PROVISION OF ROOF REPLACEMENT AT WINNIPEG TRANSIT  
DEPARTMENT  
421 OSBORNE STREET**

ISSUED: May 21, 2004  
BY: Coleen Groening /clg  
TELEPHONE NO. (204) 986-2491

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: 20040128

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.**

---

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read:

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, **June 04, 2004.**

### **PART E – SPECIFICATIONS**

Add: **E14.**

#### **E14. REPLACEMENT OF STRIPPING ON SECTION G (APPROXIMATELY 500 FT)**

E14.1 Remove existing rubber membrane and loose materials.

E14.2 Scrape back 18 inches on to roof mat.

E14.3 Install 1/2inch PWF plywood pinned to concrete wall 16 inches on centre double row.

E14.4 Prime with specified manufacturers material.

E14.5 Torch with 180 Base and 250 Cap (Grey) SBS material

E14.6 Supply and install term bar 2 inches down on plywood and 3 inches above pinned to concrete plywood and caulk pocket.

Add: **E15.**

#### **E15. TEST CUT.**

E15.1 Contractor will have to make test cut if required.