



DESIGN "D"

TOLERANCE ON HEATED LENGTH IS ±3%

RESISTANCE TOLERANCE ±10%

ITEM #	HEATER TAG	QTY.	DESIGN	CABLE REFERENCE	CABLE DIA. (IN.)	HEATER LENGTH (FT.)	WATTAGE	VOLTAGE	LEAD IN			JOINT TYPE	GLAND SIZE (NPT)	TAIL LGTH. (IN.)	RESISTANCE (OHMS)
									LGTH. (FT.)	REF.	AWG				
	LOOP #1	1	D	62HE4440	0.42	411	6652	347	7	2/10-449V	10	Y	3/4"	6"	18.1
	LOOP #4	1	D	62HE4440	0.42	411	6652	347	7	2/10-449V	10	Y	3/4"	6"	18.1
	LOOP #2	1	D	62HE4440	0.42	418	6548	347	7	2/10-449V	10	Y	3/4"	6"	18.4
	LOOP #5	1	D	62HE4440	0.42	418	6548	347	7	2/10-449V	10	Y	3/4"	6"	18.4

tyco
Flow Control

Tyco Thermal Controls

250 WEST ST.
TRENTON, ONTARIO
K8V 5S2



PROJECT NAME: PROVENCHER BRIDGE
 CONSULTANT:
 CUSTOMER: WESTBURNE WINNIPEG
 CUSTOMER PO: (WBE)76635D
 CONTRACTOR:

DWG. No.

DATE:

19-Nov-02

CUSTOM FABRICATED TYPE M.I. HEATING CABLE UNIT

DRAWING FILE: HTRIEXCELDES-D