



DESIGN "D"

TOLERANCE ON HEATED LENGTH IS ±3%

RESISTANCE TOLERANCE ±10%

ITEM #	HEATER TAG	QTY.	DESIGN	CABLE REFERENCE	CABLE DIA. (IN.)	HEATER LENGTH (FT.)	WATTAGE	VOLTAGE	LEAD IN			JOINT TYPE	GLAND SIZE (NPT)	TAIL LGTH. (IN.)	RESISTANCE (OHMS)
									LGTH. (FT.)	REF.	AWG				
	LOOP #7	1	D	62SQ3286	0.25	175	2400	347	7	2/14-371V	14	X	1/2"	6"	50.05
	LOOP #9	1	D	62SQ3286	0.25	175	2400	347	7	2/14-371V	14	X	1/2"	6"	50.05
	LOOP #8	1	D	62SQ3200	0.25	203	2950	347	7	2/14-371V	14	X	1/2"	6"	40.6
	LOOP #10	1	D	62SQ3200	0.25	203	2950	347	7	2/14-371V	14	X	1/2"	6"	40.6

tyco
Flow Control

250 WEST ST.
TRENTON, ONTARIO
K8V 5S2



Tyco Thermal Controls

PROJECT NAME:

PROVENCHER BRIDGE

DWG. No.

CONSULTANT:

CUSTOMER:

WESTBURNE WINNIPEG

CUSTOMER PO:

(WBE)76635D

CONTRACTOR:

DATE:

19-Nov-02

CUSTOM FABRICATED TYPE M.I. HEATING CABLE UNIT

DRAWING FILE: HTR\EXCEL\DES-D