



## **ADDENDUM NO. 1 BID OPPORTUNITY NO. 46-2005**

**ASBESTOS REMEDIATION – 510 MAIN STREET, 2<sup>ND</sup> FLOOR  
ADMINISTRATION BUILDING**

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 16, 2005  
BY: TRoziere /gfn  
TELEPHONE NO. (204) 986-4623

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: 20040128

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

Revise: E43.1 By adding:

“The spray on fireproofing insulation requires a two (2) hour rating.”