

REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
2	C-JY-H953B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953B	MCC 2B Protection Relay Comm. Cable	
2	C-JY-H954A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954A	MCC 3A Protection Relay Comm. Cable	
2	C-JY-H954B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954B	MCC 3B Protection Relay Comm. Cable	
2	C-JY-H955A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955A	Main Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	
2	C-JY-H955B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955B	Main Building 4160/600 VAC XFMR B Protection Relay Comm. Cable	
2	C-JY-H961A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H961A	SWGR 2A Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-JY-H961B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H961B	SWGR 2B Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-JY-H962A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H962A	MCC 4A Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-JY-H962B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H962B	MCC 4B Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-JY-H965A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H965A	Bulk Chemical Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-JY-H965B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JY-H965B	Bulk Chemical Building 4160/600 VAC XFMR B Protection Relay Comm. Cable	Not in Contract 742-2005.
2	C-LCP-F01A-C01	24-Strand 50/125/250 um Multi-mode		LCP-F02A Filters 5-8 Communication Panel	LCP-F01A Filters 1-4 Communication Panel	Plant Communication	
2	C-LCP-F02A-C01	24-Strand 50/125/250 um Multi-mode		CP-C11A Polymer Communication Panel	LCP-F02A Filters 5-8 Communication Panel	Plant Communication	
2	C-LCP-F911A-C02	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-F911A Filter Backwash Pump 1 Control Panel	Filter Backwash Pump 1 Motor Protection Relay Status	
2	C-LCP-F921A-C02	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-F921A Filter Backwash Pump 2 Control Panel	Filter Backwash Pump 2 Motor Protection Relay Status	

NOTES:   Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	B.M. ELEV.			 		ENGINEER'S SEAL		<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>		
				DESIGNED BY	SWT	CHECKED BY	SWT			ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29
				DRAWN BY	SWT	APPROVED BY	AHL	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL		
	2	742-2005 ADDENDUM 13	06/06/30	BT	SCALE: <b>NTS</b>		RELEASED FOR CONSTRUCTION BY:			CITY FILE NUMBER SHEET 9 OF 11
	1	742-2005 ADDENDUM 6	06/05/25	SWT			R. SOROKOWSKI	CITY DRAWING NUMBER 1-0601H-K-A0609-001-02B		
0	ISSUED FOR TENDER	06/03/29	SWT							
	NO. REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		
							CONSULTANT DRAWING NO.			
							WH-A0609			

June 30, 2006