




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-CP-O31-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O31	Ozone Generator 1 PLC Plant Control Network Cable	
0	C-CP-O32-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O32	Ozone Generator 2 PLC Plant Control Network Cable	
0	C-CP-O33-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	CP-O33	Ozone Generator 3 PLC Plant Control Network Cable	
0	C-CP-P31-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P31 DAF Basins 1-4 Control Panel	DAF Control	
0	C-CP-P32-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P32 DAF Basins 5-8 Control Panel	DAF Control	
0	C-LCP-F01-C01	1-Coaxial RG-6		LCP-F01A Filters 1-4 Communication Panel	LCP-F01	Filters 1-4 Remote I/O	
0	C-LCP-F02-C01	1-Coaxial RG-6		LCP-F02A Filters 5-8 Communication Panel	LCP-F02	Filters 5-8 Remote I/O	
0	C-LCP-H10-C01	1-Coaxial RG-6		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-H10 Electrical Room No. 1 Control Panel	Electrical Room No. 1 Remote I/O	
0	C-LCP-P010A-C01	4-Pair #24 AWG - Cat 5E		LCP-P11A DAF Train 1 Recycle Pump Control Panel	LCP-P010A DAF Recycle Pump 1 VFD	DAF Recycle Pump 1 VFD Control	
0	C-LCP-P020A-C01	4-Pair #24 AWG - Cat 5E		LCP-P11A DAF Train 1 Recycle Pump Control Panel	LCP-P020A DAF Recycle Pump 2 VFD	DAF Recycle Pump 2 VFD Control	
0	C-LCP-P030A-C01	4-Pair #24 AWG - Cat 5E		LCP-P11A DAF Train 1 Recycle Pump Control Panel	LCP-P030A DAF Recycle Pump 3 VFD	DAF Recycle Pump 3 VFD Control	
0	C-LCP-P040A-C01	4-Pair #24 AWG - Cat 5E		LCP-P12A DAF Train 2 Recycle Pump Control Panel	LCP-P040A DAF Recycle Pump 4 VFD	DAF Recycle Pump 4 VFD Control	
0	C-LCP-P050A-C01	4-Pair #24 AWG - Cat 5E		LCP-P12A DAF Train 2 Recycle Pump Control Panel	LCP-P050A DAF Recycle Pump 5 VFD	DAF Recycle Pump 5 VFD Control	
0	C-LCP-P060A-C01	4-Pair #24 AWG - Cat 5E		LCP-P12A DAF Train 2 Recycle Pump Control Panel	LCP-P060A DAF Recycle Pump 6 VFD	DAF Recycle Pump 6 VFD Control	
0	C-LCP-P11A-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P11A DAF Train 1 Recycle Pump Control Panel	DAF Train 1 Recycle Pump VFD Control	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
			DESIGNED BY	SWT	CHECKED BY	SWT		
			DRAWN BY	SWT	APPROVED BY	AHL	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	
	2	742-2005 ADDENDUM 13	06/06/30	BT	SCALE:	RELEASED FOR CONSTRUCTION BY:		
	1	742-2005 ADDENDUM 6	06/05/25	SWT	NTS	R. SOROKOWSKI	CITY DRAWING NUMBER 1-0601H-K-A0602-001-02B	
0	ISSUED FOR TENDER	06/03/29	SWT	DATE	2006/03/29	AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29
							CONSULTANT DRAWING NO.	WH-A0602

June 30, 2006