




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-LCP-P12A-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P12A DAF Train 2 Recycle Pump Control Panel	DAF Train 2 Recycle Pump VFD Control	
0	C-LCP-P31-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P31 DAF Basin 1 VFD Control Panel	DAF Basin 1 VFD Control	
0	C-LCP-P32-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P32 DAF Basin 2 VFD Control Panel	DAF Basin 2 VFD Control	
0	C-LCP-P33-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P33 DAF Basin 3 VFD Control Panel	DAF Basin 3 VFD Control	
0	C-LCP-P34-C01	4-Pair #24 AWG - Cat 5E		CP-P31 DAF Basins 1-4 Control Panel	LCP-P34 DAF Basin 4 VFD Control Panel	DAF Basin 4 VFD Control	
0	C-LCP-P35-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P35 DAF Basin 5 VFD Control Panel	DAF Basin 5 VFD Control	
0	C-LCP-P36-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P36 DAF Basin 6 VFD Control Panel	DAF Basin 6 VFD Control	
0	C-LCP-P37-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P37 DAF Basin 7 VFD Control Panel	DAF Basin 7 VFD Control	
0	C-LCP-P38-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P38 DAF Basin 8 VFD Control Panel	DAF Basin 8 VFD Control	
0	C-LCP-R21-C01	1-Coaxial RG-6		LCP-R21A Residuals Communication Panel	LCP-R21	Residuals Remote I/O	
0	C-LCP-S11-C01	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	Not in Contract 742-2005.
0	C-LCP-T11-C01	1-Coaxial RG-6		LCP-T11A Clearwell Communication Panel	LCP-T11	Clearwell Remote I/O	Not in Contract 742-2005.
0	C-WTPAPRTR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPAPRTR01	Router/Gateway Network Cable	
0	C-WTPAPRTR02-C01	4-Pair #24 AWG - Cat 5E		CP-D01A DBPS Communication Panel	WTPAPRTR02	Existing DBPS PLC Network Switch Network Cable	Not in Contract 742-2005.
0	C-WTPSVES01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Control Network Cable	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
			DESIGNED BY	SWT	CHECKED BY	SWT			ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29
			DRAWN BY	SWT	APPROVED BY	AHL	CONSULTANT DRAWING NO. WH-A0603	SHEET 3 OF 11	
	2	742-2005 ADDENDUM 13	06/06/30	BT	SCALE:	RELEASED FOR CONSTRUCTION BY:		AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST	1-0601H-K-A0603-001-02B
	1	742-2005 ADDENDUM 6	06/05/25	SWT	NTS	R. SOROKOWSKI			
0	ISSUED FOR TENDER	06/03/29	SWT	DATE	2006/03/29	DATE	2006/03/29		
NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29		

June 30, 2006