




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
2	C-JT-H952A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952A	MCC 1A Power Meter Comm. Cable	
2	C-JT-H952B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952B	MCC 1B Power Meter Comm. Cable	
2	C-JT-H953A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953A	MCC 2A Power Meter Comm. Cable	
2	C-JT-H953B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953B	MCC 2B Power Meter Comm. Cable	
2	C-JT-H954A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954A	MCC 3A Power Meter Comm. Cable	
2	C-JT-H954B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954B	MCC 3B Power Meter Comm. Cable	
2	C-JT-H961A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961A	SWGR 2A Power Meter Comm. Cable	Not in Contract 742-2005.
2	C-JT-H961B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961B	SWGR 2B Power Meter Comm. Cable	Not in Contract 742-2005.
2	C-JT-H962A-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962A	MCC 4A Power Meter Comm. Cable	
2	C-JT-H962B-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962B	MCC 4B Power Meter Comm. Cable	
2	C-JY-H951A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951A	SWGR 1A Protection Relay Comm. Cable	
2	C-JY-H951B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951B	SWGR 1B Protection Relay Comm. Cable	
2	C-JY-H952A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952A	MCC 1A Protection Relay Comm. Cable	
2	C-JY-H952B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952B	MCC 1B Protection Relay Comm. Cable	
2	C-JY-H953A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953A	MCC 2A Protection Relay Comm. Cable	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.			 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
				DESIGNED BY	SWT	CHECKED BY	SWT			ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	
				DRAWN BY	SWT	APPROVED BY	AHL	CONSULTANT DRAWING NO. WH-A0608			
				SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI				WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST	
				NO.	REVISIONS	DATE	BY	DATE	2006/03/29		

June 30, 2006