




CP-H11A	Generator Communication Panel				
Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
0					
0	Power Meter: Generator 1	RJ-45 To Switch 1: 01	01		
0	Power Meter: Generator 2		02	RJ-45	TBA Gen-1
0	Power Meter: Generator 3		03	RJ-45	TBA Gen-2
0	Protection Relay: Generator 1		04	RJ-45	TBA Gen-3
0	Protection Relay: Generator 2		05	RJ-45	TBA Gen-4
0	Protection Relay: Generator 3		06	RJ-45	TBA Gen-5
0	Neutral Grounding Resistor		07	RJ-45	TBA Gen-6
0			08	RJ-45	TBA Gen-7

<p>NOTES:</p> <p>1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.</p>	B.M. ELEV.				 		ENGINEER'S SEAL		<p>THE CITY OF WINNIPEG</p> <p>WATER AND WASTE DEPARTMENT</p> <p>ENGINEERING DIVISION</p>				
					DESIGNED BY	SWT	CHECKED BY	SWT			<p>ORIGINAL SIGNED BY</p> <p>S.W. TORMEY</p> <p>2006/03/29</p>		
					DRAWN BY	SWT	APPROVED BY	AHL	<p>CONSULTANT DRAWING NO.</p> <p>WH-A0509</p>				
					SCALE:		RELEASED FOR CONSTRUCTION BY:		<p>WATER TREATMENT PLANT</p> <p>PLANT UTILITIES</p> <p>MECHANICAL AND ELECTRICAL</p>				
					NTS		R. SOROKOWSKI		<p>AUTOMATION / I AND C</p> <p>PLANT COMMUNICATION CABLE</p> <p>TERMINATION DIAGRAMS</p>				
 <p>Certificate of Authorization</p> <p>Earth Tech Canada Inc.</p> <p>No. 730 Expiry: April 30, 2006.</p>				NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	CITY FILE NUMBER	
				1	742-2005 ADDENDUM 6	06/05/25	SWT			SHEET	9	OF	88
				0	ISSUED FOR TENDER	06/03/29	SWT					CITY DRAWING NUMBER	1-0601H-J-A0509-001-01B

Thursday, May 25, 2006