




Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
		PP1			
0	Plant Control Network Receive	Switch 1: 07-Rx	01	C-CP-H31A-C01	12-Strand 62.5/125 um Multi-mode TO CP-P31A
0	Plant Control Network Transmit	Switch 1: 07-Tx	02		
0	Remote I/O Network Receive	PP1: 15	03		
0	Remote I/O Network Transmit	PP1: 16	04		
0	Plant Monitoring Network Receive	Switch 2: 07-Rx	05		
0	Plant Monitoring Network Transmit	Switch 2: 07-Tx	06		
0	Spare		07		
0	Spare		08		
0	Spare		09		
0	Spare		10		
0	Spare		11		
0	Spare		12		
0	Plant Control Network Transmit	Switch 1: 08-Tx	13	C-LCP-H10A-C01	12-Strand 62.5/125 um Multi-mode TO LCP-H10A
0	Plant Control Network Receive	Switch 1: 08-Rx	14		
0	Remote I/O Network Transmit	PP1: 03	15		
0	Remote I/O Network Receive	PP1: 04	16		
0	Plant Monitoring Network Transmit	Switch 2: 08-Tx	17		
0	Plant Monitoring Network Receive	Switch 2: 08-Rx	18		
0	Spare		19		
0	Spare		20		
0	Spare		21		
0	Spare		22		
0	Spare		23		
0	Spare		24		

NOTES:  Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	B.M. ELEV.		 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0515	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
			DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER
			DRAWN BY	SWT		APPROVED BY	AHL		SHEET 15 OF 88
	1	742-2005 ADDENDUM 6	06/05/25	SWT		SCALE:	RELEASED FOR CONSTRUCTION BY:		CITY DRAWING NUMBER
	0	ISSUED FOR TENDER	06/03/29	SWT		NTS	R. SOROKOWSKI		1-0601H-J-A0515-001-01B
	NO. REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29		