




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-JY-H952A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952A	MCC 1A Protection Relay Comm. Cable	
0	C-JY-H952B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952B	MCC 1B Protection Relay Comm. Cable	
0	C-JY-H953A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953A	MCC 2A Protection Relay Comm. Cable	
0	C-JY-H953B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953B	MCC 2B Protection Relay Comm. Cable	
0	C-JY-H954A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954A	MCC 3A Protection Relay Comm. Cable	
0	C-JY-H954B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954B	MCC 3B Protection Relay Comm. Cable	
0	C-JY-H955A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955A	Main Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	
0	C-JY-H955B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955B	Main Building 4160/600 VAC XFMR B Protection Relay Comm. Cable	
0	C-JY-H961A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H961A	SWGR 2A Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H961B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H961B	SWGR 2B Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H962A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H962A	MCC 4A Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H962B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H962B	MCC 4B Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H965A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H965A	Bulk Chemical Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H965B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H965B	Bulk Chemical Building 4160/600 VAC XFMR B Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-LCP-F01A-C01	12-Strand 62.5/125 um Multi-mode		LCP-F02A Filters 5-8 Communication Panel	LCP-F01A Filters 1-4 Communication Panel	Plant Communication	

NOTES:   <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>		
			DESIGNED BY: SWT		CHECKED BY: SWT				ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29
			DRAWN BY: SWT		APPROVED BY: AHL		WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL		
	1 742-2005 ADDENDUM 6 06/05/25 SWT		SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI				CITY FILE NUMBER SHEET 4 OF 11
	0 ISSUED FOR TENDER 06/03/29 SWT						AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		
NO. REVISIONS		DATE BY		DATE 2006/03/29		DATE 2006/03/29		CITY DRAWING NUMBER 1-0601H-K-A0604-001-01B	

Thursday, May 25, 2006