



ADDENDUM 4 BID OPPORTUNITY 37-2006

WINNIPEG WATER TREATMENT PROGRAM – SURGE TOWER CONSTRUCTION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 16, 2006
BY: Lawrence Recksiedler, C.E.T.
TELEPHONE NO. (204) 986-4246

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Delete: D3.1(y)

PART E – SPECIFICATIONS

Section 16015(R1)

Add: 2.2.6.7

All excavation for the cable trenches located east of the railway tracks (up to a point two metres from the railway tracks) shall be by method of soft-cut (water jetting method) excavation or hand excavation. The steel pipes under the railway track shall be a minimum of six metres long and installed by method of coring. The method of excavation for the portion of the trench west of the railway tracks may be by backhoe.