



DRAWING NOTES	
1	PROVIDE PROPER DUCT TRANSITION PIECE.
2	UNDERSIDE OF DUCT SHALL BE MINIMUM 2200mm ABOVE INSIDE FLOOR LEVEL TO ALLOW PROPER HEAD CLEARANCE.
3	ENTIRE O/A DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
4	ENTIRE RELIEF AIR DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
5	INTAKE HOOD SHALL INCLUDE A BIRD SCREEN AND MOTORIZED DAMPERS. THROAT SIZE SHALL BE 1050x300.
6	UNDERSIDE OF DUCT TO BE 2200 ABOVE FINISHED FLOOR.

GENERAL NOTES	
1.	COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>Frederickson Cooper ARCHITECTS</p>	<p>A Type International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	CITY FILE NUMBER		
				DESIGNED BY DC		CHECKED BY AB	ORIGINAL SIGNED BY	SHEET OF
				DRAWN BY DC		APPROVED BY AHL	2006/08/30	WATER TREATMENT PLANT TREATED WATER STORAGE INLET BUILDING
				SCALE: AS SHOWN		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WT-M0004	MECHANICAL VENTILATION SECTIONS
	NO. REVISIONS	DATE	BY	DATE				