



53-2006 ADDENDUM 2

MARYLAND TWIN BRIDGES REHABILITATION PROJECT EAST BRIDGE REHABILITATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 27, 2006
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E7.2.7(a) to read: The standard pre-mixed bagged grout for recess grouting alongside the duct may be either the duct void injection grout, the post-tensioning cable grout, or a non-shrink, cement-based grout. Approved products are SikaGrout 212, CPD Non Shrink Grout, or Meadows CG-86.
- Revise: E10.2.2(a) to read: Epoxy adhesive shall be ST 431, Dural Duralbond, Capper Capbond E, Sikadur 32 Hi-bond, Concrevice 1001 LPL, Meadows Rezi-Weld 1000, or equal as accepted by the Contract Administrator.
- Revise: E10.2.3(a) to read: Epoxy grout shall be Duralcrete as distributed by Specialty Construction Products, Dural 103 Gel, Meadows Rezi-Weld Gel Paste, or equal as accepted by the Contract Administrator.
- Revise: E10.2.4(a) to read: Grout shall be nonmetallic and nonshrink grout. Acceptable grouts are: Master Builders Set Nonshrink Grout, Sika Grout 212, Sternson M-Bed Standard Grout, CPD Nonshrink Grout, Meadows CG-86, or equal as accepted by the Contract Administrator.
- Revise: E11.2.12(a) to read: Latex bonding agent shall be Acryl Stix, as supplied by Specialty Construction Products, Planicrete AC by Mapei, Meadows Acry-Lok, or equal as accepted by the Contract Administrator. Polyvinyl acetate-based latexes will not be permitted.
- Revise: E11.2.22(a) to read: Where epoxy adhesive for concrete to concrete and to steel is used, it shall be Sternson ST432 or ST433, Dural Duralbond, Capper Capbond E, Sikadur 32 Hi-bond, Concrevice 1001 LPL, Meadows Rezi-Weld 1000, or equal as accepted by the Contract Administrator.
- Revise: E11.2.23(a) to read: Where non-shrink cementitious grout is used, it shall be Sternson M-bed Standard, Specialty Construction Products CPD Non-Shrink Grout, Sika 212 Non-Shrink Grout, Meadows CG-86, or equal as accepted by the Contract Administrator. The minimum compressive strength of the grout at 28 days shall be 40 MPa.
- Revise: E11.2.24(a) to read: Where epoxy grout is used, it shall be Sternson Talygrout 100, Sika Sikadur 42, CPD Epoxy Grout by Specialty Construction Products, Meadows Rezi-Weld EG-96, or equal as accepted by the Contract Administrator.