



429-2011 ADDENDUM 11

DESIGN AND CONSTRUCTION OF THE PUBLIC WORKS EAST YARD COMPLEX AT THE FORMER ELMWOOD NAIRN LANDFILL SITE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
REQUEST FOR PROPOSAL**

ISSUED: July 21, 2011
BY: Barry Evenson
TELEPHONE NO. (204) 794-4401

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR PROPOSAL AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20070420

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

QUESTIONS AND ANSWERS

Responses to Questions not yet answered will be included in further Addenda as the responses are developed.

Clause and Page numbering may be changed as a result of Addendum. Please read the revised clauses carefully.

GENERAL PROPONENT QUESTIONS

PQ101 SA28 Exterior Vehicle & Equipment slab – Can you confirm the wash water treatment is required?

PA 101 Wash water treatment is optional for SA-28, but recommended for LEED® credits.

PQ102 CS 13 & CS 14 – Can you confirm you require grit separators and drainage to these locations?

PA 102 Yes these are required.

PQ103 Cistern – Please confirm size of cistern 800m³?

PA 103 The 800m³ cistern requirement is related to a rooftop rainwater collection system with sizing based on a design storm event as per the National Building Code/National Plumbing Code

PQ104 SM13 – Can you confirm you require drainage to these locations?

PA 104 Yes, drainage is required at SM13.

PQ105 Please advise the municipal address of the site and its current zoning.

PA 105 The site does not have a street address as of yet. An address will be issued when the building is constructed. According to Schedule B - Zoning Maps #9 and #14 (available on the City of Winnipeg Website at: http://winnipeg.ca/ppd/zoning_6400_keymap2.stm), the west half (approximately) of the site is zoned M3 – Manufacturing – Heavy and the east half is zoned M2 – Manufacturing – General.