LINE TYPE

	DOMESTIC COLD WATER
	DOMESTIC COLD WATER - EXISTING
PS	POOL WATER SUPPLY - NEW
PS	POOL WATER SUPPLY - EXISTING
PR	POOL WATER RETURN - NEW
PR	POOL WATER RETURN - EXISTING
	POOL WATER - TO BE REMOVED
— — HWR— — —	HEATED POOL WATER RETURN
HWS	HEATED POOL WATER SUPPLY

SYMBOLS

——⋈——	SHUT-OFF VALVE
	CHECK VALVE
	CONCENTRIC REDUCER
	PRESSURE REDUCING VALVE
_,l,	TEE
——ф——	BALL VALVE
——————————————————————————————————————	BUTTERFLY VALVE
I	UNION
	FLANGE
	STRAINER
RPBFP	REVERSE PRESSURE BACK FLOW PREVENTER
	DIRECTION OF FLOW
91	PRESSURE GAUGE
O	PUMP
M	WATER METER
0	PIPE RISE
·	PIPE DROP
EQ-##	FIXTURE TAG
NO.	GENERAL NOTE
A	DEMOLITION NOTE
1 M1.1	DRAWING HEADER

GENERAL NOTES

- ALL NEW PIPING TO BE SCH. 80 PVC, CERTIFIED FOR USE WITH POOL WATER.
- INSTALL ALL NEW HANGERS ON NEW AND RELOCATED PIPE. CONNECT TO UNDERSIDE OF STRUCTURE.
- PROVIDE COUPLINGS BETWEEN STEEL AND PVC PIPE WHERE CONNECTIONS ARE MADE TO EXISTING SYSTEM.
- KEY NOTES ON M-2 ARE REFERENCED ON ALL DRAWING PAGES.





No. 4035 Date: 12.04.11

) 1

ADDENDUM 1

DE 12.04.12 DE 12.04.05

NO.

REVISION/DESCRIPTION

FOR CONSTRUCTION

BY DATE

epp siepman engineering inc. mechanical engineers

303-100 Osborne St. South Winnipeg, MB R3L 1Y5

p 204.453.1080 f 204.453.1335 ese@eppsiepman.com

DRAWN BY

CAD CHECKED BY
2012.04.04 USER APPROVAL

Y APPROVED



CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
CIVIC ACCOMMODATIONS DIVISION
300 - 65 GARRY ST. R3C 4K4

PROJECT

ULTRAVIOLET SYSTEM

AND PUMP UPGRADES 909 CONCORDIA AVE.

SHEET TITLE


SCHEMATIC AND LEGENDS

SCALE	PROJECT NO.	SHEET NO.
AS SHOWN	118-2012	M-4 R1

CIRCULATION PUMP SCHEDULE

MARK	MAKE/MODEL	PUMP TYPE	SIZE	Impelle	er Size	SERVES	RVES FLOW		HEAD		NPSHr	MOTOR		VOLTAGE	SUCTION	DISCHARGE	NOTES
0 4	(based on)		25	mm	in		lpm	gpm	kPa	ft	ft	kW	HP	20	in	in	
P-1 & 2	B & G Series 1510	End Suction Base Mounted	6G	340	13.375	POOL	4997	1320	209	70	9.24	30	40	575/3	8	6	1,2,3

- 1. Confirm voltage with electrical drawings.
- Duty/Standby Manual change over of pumps
- 3. Pumps for use with chlorinated pool water. Pump to be supplied with wetted parts coated with appropriate epoxy coating.



SCALE: N.T.S.