



242-2012ADDENDUM 1

ROOF REPLACEMENT AT GATEWAY ARENA-1717 GATEWAY ROAD

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 10, 2012
BY: Norm Carrothers
TELEPHONE NO. (204) 794-4400

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E4.4 to read: Alter all gas lines and electrical as required to accommodate the new roofing. Gas lines that feed Arena boiler will have to be rerouted and remain in service to provide hot water for arena showers etc.