



490-2012 ADDENDUM 2

MACLEAN PUMPING STATION ELECTRICAL UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 23, 2012
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: Clause B2.1 to read:

The Submission Deadline is 4:00pm Winnipeg time, September 4, 2012.

PART E – SPECIFICATIONS

Revise: 26 05 21 Clause 2.1.3.3 to read:

1000 V insulation of chemically cross-linked thermosetting polyethylene material rated RW90 or RWU90.

DRAWINGS

Replace: 490-2012_Addendum_1_Drawing_1-0630M-E0023-001-01 with
490-2012_Addendum_2_Drawing_1-0630M-E0023-001-02

Replace: 490-2012_Drawing_1-0630M-E0024-001-00 with 490-2012_Addendum_2_Drawing_1-0630M-E0024-001-01

Replace: 490-2012_Drawing_1-0630M-E0040-001-00 with 490-2012_Addendum_2_Drawing_1-0630M-E0040-001-01

Replace: 490-2012_Drawing_1-0630M-E0063-001-00 with 490-2012_Addendum_2_Drawing_1-0630M-E0063-001-01

Replace: 490-2012_Drawing_1-0630M-E0064-001-00 with 490-2012_Addendum_2_Drawing_1-0630M-E0064-001-01

Replace: 490-2012_Drawing_1-0630M-E0065-001-00 with 490-2012_Addendum_2_Drawing_1-0630M-E0065-001-01

OTHER DOCUMENTS

Replace: 490-2012_Addendum_1_Cable_Schedule with 490-2012_Addendum_2_Cable_Schedule