



RFP No.541-2012 ADDENDUM No. 1

FOR PROFESSIONAL CONSULTING SERVICES FOR DETAILED DESIGN AND CONTRACT ADMINISTRATION SERVICES FOR THE WESTWOOD WASTEWATER PUMPING STATION STANDBY ENGINE REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
REQUEST FOR PROPOSAL**

ISSUED: July 12,2012
BY: Doug Berg, C.E.T.
TELEPHONE NO. (204) 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR PROPOSAL AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20070420

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D3.3 (a) to read: Replace the standby natural gas engine, including the centrifugal clutch component, along with associated engine controls.

PART E – SCOPE OF SERVICES

Revise: E1.4 (a)(i) to read: Design and preparation of specifications for the new replacement engine, including a new replacement centrifugal clutch.