

712-2013 ADDENDUM 5

PLESSIS ROAD TWINNING AND GRADE SEPARATION AT CN REDDITT SUBDIVISION: PLESSIS ROAD RECONSTRUCTION, UNDERPASS STRUCTURES, PUMPING STATION, LAND DRAINAGE SEWER AND MISCELLANEOUS UNDERGROUND AND LANDSCAPING WORKS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 4, 2014
BY: Barry Biswanger, P.Eng.
TELEPHONE NO. (204) 928-7411

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

NMS SPECIFICATIONS

DIVISION 5

- Replace: 2.1.13 in Section 05 50 00: Floor Hatches: cover and frame shall be aluminum. Hinges: Type 316 stainless steel. Slam lock with fixed interior handle and removable exterior turn and lift handle with removable gasketed screw plug, lift assistance and automatic hold open device: Type A316 stainless steel. All hardware to be Type 316 stainless steel. All hatches exposed to ambient temperatures shall be insulated with 50 mm of concealed polystyrene foam.
- Replace: 2.1.13.1 in Section 05 50 00: Single leaf hatches shall be Bilco Type J-AL, or approved equal in accordance with B8.
- Replace: 2.1.13.2 in Section 05 50 00: Double leaf hatches shall be Bilco Type JD-AL, or approved equal in accordance with B8.

DIVISION 40

- Replace: 2.2.3.1.2 in Section 40 23 13.01: Flanges to conform to ANSI/ASME B16.5-2013 Class 150.

DRAWINGS

- Replace: 712-2013 _Drawing_U238-2014-2331-R0 with 712-2013 _Addendum_5 -Drawing_U238-2014-2331-R1