



## 79-2013 ADDENDUM 2

### BISHOP GRANDIN BLVD/SHOREHILL DR TO BEAVERHILL BLVD: MULTI-USE PATH AND NAVIN DRAIN CAST-IN-PLACE CONCRETE CULVERT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 11, 2013  
BY: Craig Rowbotham  
TELEPHONE NO. (204) 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, February 14, 2013.

#### **PART E – SPECIFICATIONS**

Replace: E18.2.10(a) with the following:

E18.2.10 Concrete Mix Design

- (a) The Contractor shall be responsible for the design and performance of all concrete mixes supplied under this Specification. Concrete shall be supplied in accordance with the requirements of CSA A23.1-04, with the minimum properties as provided below:

Class of Exposure	C-1
Maximum Size of Aggregate (mm)	20 mm
Cement Type	Type Gu
Maximum Water/Cementing Materials Ratio	0.40
Compressive Strength at 56 Days	35 MPa
Slump/Flow	80 +/- 20 mm
Air Content	4-7%