



424-2014 ADDENDUM 1

WATER TREATMENT PLANT CIVIL MAINTENANCE/AQUEDUCT STORAGE BUILDING SITE SERVICES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 19, 2014
BY: Jeff Brooks, C.E.T.
TELEPHONE NO. (204) 986-2521

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 424-2014 Bid Submission with 424-2014 Addendum 1- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Revise Item 13 Description to "Supply and install two 150mm dia. HDPE electrical conduit by HDD".
- Form B(R1): Revise Item 13 Units to "300".
- Form B(R1): Revise Item 14 Description to "Supply and install two 150mm dia. penetration and double water seals for electrical conduits below grade at Deacon Booster Pump Station".
- Form B(R1): Revise Item 14 Units to "2".
- Form B(R1): Add Items No. 18 to 19 inclusive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2(g) to read: Supply and installation of approximately two150 m of 150 mm HDPE electrical conduit from the Deacon Booster Pump Station to the new Civil Maintenance/Aqueduct Storage Building. Provide new penetration into the Deacon Booster Pump Station with appropriate water-stop. Terminate the conduit above ground at the new Civil Maintenance/Aqueduct Storage Building;