

824-2014 ADDENDUM 3

WESTON MEMORIAL COMMUNITY CENTRE RENOVATION 1625 LOGAN AVENUE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 27th, 2014
BY: Jen Rac
TELEPHONE NO. (204) 943-5087

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

DIVISION 1

SECTION 01 51 00 – TEMPORARY UTILITIES

Add 1.2.3 to read: Contractor is responsible to pay for all water supply, heating and ventilation, power and lighting within the community centre for the duration of the work beginning once the building is turned over to the Contractor until Total Performance is achieved.

Add 1.2.4 to read: Contractor to supply portable washroom facilities if required. Contractor is responsible for cleaning and maintaining washroom facilities throughout the duration of the Work.

SECTION 01 56 00 – TEMPORARY BARRIERS AND ENCLOSURES

Revise 1.3.1 to read: Provide construction site fencing around areas of Work as required.

Revise 1.3.1.1 to read: Erect temporary site enclosure using pre-manufactured steel chain link fence, 2400mm height, adequately braced and connected to resist collapse.

DIVISION 8

SECTION 08 71 00 – DOOR HARDWARE

Add to 3.6.3: Hardware Set #1: Approved Equal: Besam, Model SW200i Automatic Door Operator.

Hardware Set #5: Approved Equal: Besam, Model SW200i Automatic Door Operator.

SECTION 08 80 50 – GLAZING

Add 2.1.3.2: Full Length Mirror: 762mm x 1372mm, 6mm tempered mirror glass

Add 2.1.3.2.1 Schedule: Men's Washroom M11, Washroom M13, Women's Washroom M14, and Universal Washroom M30.

Add 2.1.3.3: Vanity Mirror: 1100mm x length as required, 6mm tempered mirror glass

Add 2.1.3.2.1 Schedule: Men's Washroom M11 and Women's Washroom M14 as shown on drawings.

DIVISION 9

SECTION 09 22 27 – ACOUSTICAL SUSPENSION

Add spec section 824-2014_092227_R0.

SECTION 09 51 13 – ACOUSTICAL PANEL CEILINGS

Add spec section 824-2014_095113_R0.

ROOM FINISH SCHEDULE

Replace 824-2014_Room_Finish_Schedule_R1 with 824-2014_Room_Finish_Schedule_R2. (Note that MPR #2 M28 has t-bar ceiling).

DIVISION 10

SECTION 10 28 10 – TOILET AND BATH ACCESSORIES

Delete item 2.2.10: Note: Full length mirrors to be added under specification section 08 80 50 Glazing.

DRAWINGS

Replace: 824-2014_Drawing_A-2-0_R0 with 824-2014_Drawing_A-2-0_R1.

824-2014_Drawing_M0-0_R0 with 824-2014_Drawing_M0-0_R5.