

1002-2016 ADDENDUM 5

DESIGN AND INSTALLATION OF NEW LED VIDEO DISPLAY BOARD - PAN AM INDOOR POOL - 25 POSEIDON BAY

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: December 13, 2016 BY: Lou Chubenko TELEPHONE NO. 204 986-2727

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B - BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, December 16, 2016.

PART E - SPECIFICATIONS

Section 10 14 00 Video Display System

Add: 2.2.6 The Contract Administrator approves as a substitute the DAKTRONICS Model No. DVX-

1801-10MN-6000-WN 10mm colour indoor digital sign with sealed modules, rear service access and is completely compatible with Swiss Timing equipment as an "approved equal" to the specified Media Resources Vision IQ video display Model No. P10-RGB-

672-416, in accordance with Clause B7.