



## 349-2016 ADDENDUM 2

### INSTALL CCTV SYSTEM 3 POOL/REC CENTER LOCATIONS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 3, 2016  
BY: Joe Barnes  
TELEPHONE NO. 204 470-7340

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

- Add: D2.2(b) vi Install monitor, power plug and cabling per drawing Sherbrook A04 – New CCTV Camera Locations Main Floor Addendum 2
- Revise: D2.2(b) to read: The Contractor shall supply and install new **CAT 6 (FT4 indoor, FT6 outdoor)** Cables to locations of cameras as per drawing mark as Pan Am A01 – New CCTV Camera Locations Main Floor, Pan Am A02 New CCTV Camera Locations 2<sup>nd</sup> Floor, Sherbrook A04 – New CCTV Camera Locations Main Floor, Pan Am Sherbrook A05 New CCTV Camera Locations 2<sup>nd</sup> Floor, CKRC Pool A07 – New CCTV Camera Locations Main Floor, CKRC Pool A08 New CCTV Camera Locations 2<sup>nd</sup> Floor

#### **DRAWINGS**

- Replace: 349-2016\_Drawing\_A04-R0 with 349-2016\_Addendum\_2-Drawing\_A04-R1
- 349-2016\_Drawing\_A07-R0 with 349-2016\_Addendum\_2-Drawing\_A07-R1