



## 975-2016 ADDENDUM 1

### 2017 OUTFALL RENEWAL AND REHABILITATION

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: Nov 15, 2016  
BY: Ray Offman  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: 975-2016 Bid Submission with 975-2016 Addendum 1 Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1):
- Change B.5.a to read: 1660 mm Diameter SPCSP (3.0 mm) c/w Copolymer Coating, Class B Type 1 Bedding, Class 4 Backfill
  - Change B.9.b to read: 250 mm to 500 mm diameter
  - Change C.3.d to read: 300 mm diameter (1.6mm) CSP c/w polymer coating, Class B Type 4 Bedding, Class 4 Backfill
  - Change C.6.a to read: 300 mm diameter
  - Change C.10.b to read: 250 mm to 500 mm diameter
  - Change C.19.a to read: Outfall pipe (82 m - 250 mm diameter PVC, 11 m - 300 mm diameter CMP)
  - Add Item No. D.12 - Straw Mulch
  - Change E.5.a to read: 22.5 degree bend - 375 mm diameter PVC
  - Add Item No. E.17 - Straw Mulch
  - Change G.10.b to read: 250 mm to 500 mm diameter

Page numbering on some forms may be changed as a result.

#### **PART E – SPECIFICATIONS**

- Revise: E16.4.2.d.g to read: 1660 mm diameter SPCSP (3.0 mm) c/w copolymer coating
- Revise: E16.4.3.c.d to read: 22.5 degree bend – 375 mm diameter PVC

**DRAWINGS**

Replace: 975-2016 \_Drawing\_LD7986-R0 with 975-2016\_Addendum\_1-Drawing\_LD7986-R1  
975-2016 \_Drawing\_LD7988-R0 with 975-2016\_Addendum\_1-Drawing\_LD7988-R1  
975-2016 \_Drawing\_LD7990-R0 with 975-2016\_Addendum\_1-Drawing\_LD7990-R1  
975-2016 \_Drawing\_LD7992-R0 with 975-2016\_Addendum\_1-Drawing\_LD7992-R1  
975-2016 \_Drawing\_LD7993-R0 with 975-2016\_Addendum\_1-Drawing\_LD7993-R1