A1 SIZE – 594mm x 841mm



ROOF PLAN

1 : 50



GENERAL NOTES:

1. REFER TO DWG. 1–0102–ELTG–K002–001 FOR LIGHTING GENERAL NOTES.

SPECIFIC NOTES:

1. PROVIDE A LINE VOLTAGE LIGHT SWITCH FOR EXTERIOR ROOF MOUNTED 347V LUMINAIRES. THE SWITCH SHALL PROVIDE MANUAL OVER–RIDE 'OFF' OF THE LUMINAIRES FED FROM THE PHOTOCELL "ON, TIME CLOCK "OFF" EXTERIOR LIGHTING CONTROL SYSTEM. REFER TO DWG. 1–0102–ELTG–K005 FOR EXTERIOR LIGHTING CONTROL SCHEMATIC.
2. LUMINAIRE TO BE UN–SWITCHED ON ESSENTIAL LIGHTING CIRCUIT. TYPICAL.
3. LUMINIARES NOT SHOWN ON PLAN DRAWINGS BUT ONLY ON SECTION HEREIN.



A SECTION

1 : 50

REFERENCE DRAWINGS	DESCRIPTION
1–0102–ELTG–K002	LIGHTING PLAN LAYOUT – GROUND FLOOR
1–0102–ELTG–K005	EXTERIOR LIGHTING CONTROL SCHEMATIC – LC–K725
1–0102–ESCH–K001	PANEL SCHEDULES & DETAILS
1–0102–ESCH–A002	SCHEDULE – LUMINAIRE AND EXIT SIGNS

1:50 500 0 1000 2000

APEGM Certificate of Authorization
SNC-Lavalin Inc.
No. 4489

NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR CONSTRUCTION – 976–2016	2017/04/05	SLJ	DEB

CH2MHILL. SNC·LAVALIN KGS GROUP

DESIGNED BY: S. JUGANAS	CHECKED BY: E. RYCZKOWSKI
DRAWN BY: MJ. PERSSON	APPROVED BY: D. BECKER
SCALE: 1:50	ISSUED FOR CONSTRUCTION BY: J. SHUMKA
DATE: 2015/02/04	DATE: 2017/04/05
CONSULTANT NO.: 474248	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D.G. BECKER
Member
23646
REGISTERED PROFESSIONAL ENGINEER
April 5/ 2017

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
SEWPCC UPGRADING/EXPANSION PROJECT
ELECTRICAL – LIGHTING PLAN LAYOUT
HIGH RATE CLARIFICATION BUILDING
ROOF PLAN

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1–0102–ELTG–K003	001	00	A1

LAST SAVE: 2017/03/24 – 9:42am
PATH: C:\DWG\1–0102–ELTG–K003.dwg

PLOT DATE: Mar 24, 2017 – 9:42am

FILE NAME:1–0102–ELTG–K003.dwg