



381-2017 ADDENDUM 3

PAINTING OF POOL TANK CONCRETE SURFACES & RELATED WORKS AT WESTDALE OUTDOOR POOL – 550 DALE BOULEVARD

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 2, 2017
BY: Lou Chubenko
TELEPHONE NO. 204 986-2727

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E4.3 to read: All surface cracks and bug holes should be feathered out and cleaned out with wire brush and compressed air.
- Revise: E4.4 to read: Application of SIKADUR 52 or SIKADUR 31 to seal cracks for approximately 600 linear feet in area.
- Add: E4.9 Acceptable Product: SIKADUR 31, HI-MOD, a 2-component, 100% solids, moisture tolerant, high-modulus, high strength, structural epoxy paste adhesive is an approved alternate to specified SIKADUR 52, in accordance with B7.
- Revise: E5.7 to read: Apply black colour for pool markings, depth markers and concrete pool deck edge with 6" (150 mm) width band, as per location of existing markings.