



1121-2018 ADDENDUM 1

DETAILED DESIGN AND CONTRACT ADMINISTRATION – JESSIE PUMPING STATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: December 4, 2018
BY: D. Berg, C.E.T.
TELEPHONE NO. 204 - 986-4452

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART E – SPECIFICATIONS

Add: E1.1.6 (b)(xi): Provide design of new ladders inside Station, complete with rest platforms if ladder length is greater than five (5) metres.

Revise: E1.1.6 (d)(ix) to read: Provide for new installation of sump pump in the pump room of the Station;

- Provision of sump and sump pump, complete with all discharge piping and power connections in each of the Station comminutor chambers

APPENDICES

Replace: 1121-2018_Appendix_A with 1121-2018_Addendum_1-Appendix_A-R1