


SPRINKLER HEAD BELOW CEILING - REDUCING ELBOW SCALE: N.T.S.

SPRINKLER HEAD IN CONCEALED SPACE AND BELOW CEILING SCALE: N.T.S.



FIRE DEPARTMENT CONNECTION SCALE: N.T.S

FIRE PROTECTION SCHEMATIC SCALE: N.T.S

**Public City Architecture Inc** 11-600 Clifton Street Winnipeg, Manitoba R3G 2X6 204 475 9323 publiccityarchitecture.com

Rev. No. Date

Revision Notes

0 19-11-06 Issued for Construction

MECHANICAL ROOM

SPRINKLER ZONE REFER TO FIRE DEPARTMENT - CONNECTION DETAIL FOR CONTINUATION

MAIN FLOOR

REFER TO INCOMING WATER


DISCHARGE TO STANDPIPE. STANDPIPE SHALL BE AT 48" AFF — AND SHALL BE 4" (100mm) DIAMETER MINIMUM. SECURE TO WALL NEAR TOP OF STANDPIPE.



Epp Siepman Engineering Inc. No. 4035

This is a print of a document that has been electronically authenticated with technology authorized by the APEGM. The original is in electronic form.





This drawing must not be scaled. The contractors shall verify all dimensions and other data on site prior to commencement of work. Discrepancies, errors, and omissions are to be reported to Public City Architecture Inc. prior to proceeding with the Work. Drawings and specifications as instruments of service are the property of Public City Architecture Inc.; the copyright in the same being reserved.

No reproduction or revision to these drawings may be made without the permission of Public City Architecture Inc., and when made, must bear their name. All prints to be returned to Public City Architecture Inc. upon request.

Project

ST. JAMES CIVIC CENTRE

Drawing DETAILS - FIRE PROTECTION PLAN

EB

Scale: NTS

Date:

Drawn By: Review By: JS Tender No: 1176-2019 11/06/19 Sheet: MF4.1