



1195-2019 ADDENDUM 2

WAYFINDING PHASE 1 CONSTRUCTION ST. JAMES – ASSINIBOIA CENTENNIAL POOL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: December 2, 2019
BY: Lou M. Chubenko
TELEPHONE NO. 204 470-7881

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

DRAWINGS

Replace: 1195-2019_Drawing_L1.0-R0 with 1195-2019_Addendum_2-Drawing_L1.0-R1
1195-2019_Drawing_L1.2-R0 with 1195-2019_Addendum_2-Drawing_L1.2-R1

QUESTIONS AND ANSWERS

- Q1: Are final electrical connections required?
A1: Yes, all connections are required for full commission of signs.
- Q2: Are we responsible for running power to the sign location?
A2: Yes, please refer to 1195-2019_Drawing_E2.0-R0.
- Q3: Are we responsible for trenching conduit and cable?
A3: Yes, please refer to 1195-2019_Drawing_E2.0-R0.
- Q4: Are concrete bases in our scope of work?
A4: Yes, please refer to 1195-2019_Drawing_S-1-R0.
- Q5: What is the site power supply electrical voltage?
A5: Contractor to verify on site the existing site power supply electrical voltage.
- Q6: Confirm whether the reader board is to be single or double sided for pricing.
A6: The electronic reader board shall be single-sided.