



ELECTRICAL RENOVATION NOTES: "x"
 ALSO SEE NOTES & SPECIFICATIONS.
 ALL WIRING & CABLING IN CEILING SPACE SHALL BE PLENUM RATED AS PER LATEST CEC. IF REQUIRED, PROVIDE WIRE, CONDUIT, END-OF-LINE RESISTORS & BOOSTER POWER SUPPLIES.

- PROVIDE EMERGENCY BATTERY BANK 2-HEAD UNIT.
 - WIRE TO MONITOR LIGHTING CIRCUITS IN SEWING ROOM & LAUNDRY ROOM WITH REQUIRED ZONE SENSING RELAY TO ACTIVATE 2-HEAD REMOTE EMERGENCY LAMPS UPON LOSS OF POWER.
- PROVIDE NEW CEILING MOUNTED SMOKE DETECTORS. WIRE TO EXISTING SYSTEM.
 - SEWING/REPAIR SHOP; MOUNTED UNDERSIDE NEW ACOUSTIC CEILING.
 - LAUNDRY ROOM; MOUNTED UNDERSIDE ROOF DECK.
- PROVIDE NEW HORN/STROBE WITH END OF LINE (EOL) RESISTOR. CONNECT TO EXISTING CIRCUIT. MOUNT HORN STROBE 90° AFF.

EMERGENCY SIGN AND LIGHTING SCHEDULE					
TAG	DESCRIPTION	MANUFACTURER	CATALOG No.	VOLTS	BRANCH CIRCUIT
EBB-1	BATTERY UNIT W/ 2LAMP	AIMLITE	EBST06036-2MB-4WLR-WHT	120/347VAC	AS SHOWN, WIRE WITH VSR

NOTES:
 REFER TO DRAWING E1.
 INSTALLATION SHALL BE IN CONFORMANCE WITH CANULC-S524-M, STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS. NOTIFY BUILDING OWNER PRIOR TO PERFORMING A MANDATORY FIRE ALARM VERIFICATION REPORT IN CONFORMANCE WITH CANULC-S537, STANDARD FOR VERIFICATION OF FIRE ALARM SYSTEMS FOR ZONES AFFECTED.

PARTIAL REFLECTED CEILING PLAN - RENOVATION
 SCALE: 1/4"=1'-0"

No.	REVISION/DESCRIPTION	BY	DATE
1	ISSUED FOR ADDENDUM 1	DTA	2020.10.21
0	ISSUED FOR CONSTRUCTION	DTA	2020.09.30



DATE	DATE	DATE	DATE
DRAWN	CHECKED	DESIGNED	APPROVED
DATE	DATE	DATE	DATE
2020.09.15	USER		
	APPROVAL		

THE CITY OF WINNIPEG
 PLANNING, PROPERTY AND
 DEVELOPMENT DEPARTMENT
 MUNICIPAL ACCOMMODATIONS DIVISION
 3-65 GARRY STREET, R3C 4K4

PROJECT
 FPS TRAINING, REPAIR & STORAGE FACILITY
 TURN OUT GEAR LAUNDRY ROOM

2546 McPHILLIPS STREET BID OPP: 696-2020

SHEET TITLE
 PARTIAL MAIN FLOOR REFLECTED CEILING PLAN
 ELECTRICAL
 FIRE ALARM AND EMERGENCY LIGHTING

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2020-047	E3R1