



## 255-2021 ADDENDUM 1

### SURFACING AT 2546 MCPHILLIPS STREET

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: May 11, 2021  
BY: Scott Wilkinson  
TELEPHONE NO. 204 986-8294

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART E – SPECIFICATIONS**

- Revise: E3.3 to read: 18" depth of limestone installed over Geotech fabric and packed:
- (a) 10-12" of 4-6" limestone **or clean recycled concrete**;
  - (b) 6-8" of 2" limestone **or clean recycled concrete**.