



GENERAL NOTES:

FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB3	0P	5x20mm	0.1
	1P	5x20mm	0.1
	2P	5x20mm	0.1
	3P	5x20mm	0.1
	4P	5x20mm	0.1
	5P	5x20mm	0.1
	6P	5x20mm	0.1
	7P	5x20mm	0.1
	8P	5x20mm	0.1
	9P	5x20mm	0.1
	10P	5x20mm	0.1
	11P	5x20mm	0.1
	12P	5x20mm	0.1
	13P	5x20mm	0.1
	14P	5x20mm	0.1
	15P	5x20mm	0.1
	16P	5x20mm	0.1
	17P	5x20mm	0.1
	18P	5x20mm	0.1
	19P	5x20mm	0.1
	20P	5x20mm	0.1
	21P	5x20mm	0.1
	22P	5x20mm	0.1
	23P	5x20mm	0.1
	24P	5x20mm	0.1
	25P	5x20mm	0.1
	26P	5x20mm	0.1
	27P	5x20mm	0.1
	28P	5x20mm	0.1
	29P	5x20mm	0.1
	30P	5x20mm	0.1
31P	5x20mm	0.1	

10	-	-
9	-	-
8	-	-
7	-	-
6	-	-
5	-	-
4	-	-
3	-	-
2	-	-
1	-	-
NO.	DRAWING NUMBER	REFERENCE DRAWING TITLE
REFERENCE DRAWINGS		



B.M. ELEV.			
CONSTRUCTION COMPLETION DATE: YYYY MM DD			
DESIGNED BY	DG		
CHECKED BY	JAB		
DRAWN BY	RG		
APPROVED BY	JAB		
SCALE:	NTS		
RELEASED FOR CONSTRUCTION			
DATE	2022 04 11		
DATE	2022 07 05		
DATE	2022 05 18		
NO.	REVISIONS	DATE	BY
1	RE-ISSUED FOR CONSTRUCTION	2022 07 05	JAB
0	ISSUED FOR CONSTRUCTION	2022 05 18	JAB

**KGS GROUP**

DESIGNED BY DG  
CHECKED BY JAB  
DRAWN BY RG  
APPROVED BY JAB  
SCALE: NTS  
RELEASED FOR CONSTRUCTION

DATE 2022 04 11  
DATE 2022 07 05  
DATE 2022 05 18

ENGINEER'S SEAL
CONSULTANT DRAWING NUMBER
21-0107-015_A5.135

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

**Winnipeg**

NORTH END SEWAGE TREATMENT PLANT (NEWPC)  
INTERIM PHOSPHOROUS REMOVAL  
AUTOMATION

BUILDING 101  
RIO-F8000-1.R0 WIRING DIAGRAM - DISCRETE INPUT

CITY DRAWING NUMBER 1-0101-ACBD-F214-001 SHEET 6 OF 14