



Friesen Tokar Architects 200 - 2033 Portage Avenue Winnipeg, Canada R3J 0K8 Tel. 204.885.9323 Fax. 204.837.7235	
DESIGNER	AA / RC
CONTRACTOR	CB
DATE	APRIL 2004
PROJECT NO.	01216
REV. NO.	
1. ISSUED FOR 50% REVIEW FEBRUARY 6, 2004	
2. ISSUED FOR 75% REVIEW MARCH 5, 2004	
3. ISSUED FOR PRETENDER REVIEW APRIL 2004	
4. ISSUED FOR TENDER MAY 14, 2004	

SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 775 Buxton Street Winnipeg, MB Canada R3B 0S3
 Telephone: 204.772.5100 Fax: 204.772.5105
 smseng.com
 02-018-01

ORIGINAL CONTRACT DRAWING
 OWNED AND HELD BY
 ANDY LOHSE, P.ENG.
 MAY 11, 2004

APCM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 106 (Expiry: April 30, 2005)

Drawings and specifications, as prepared or approved by the architect, are the property of the architect. No reproduction or use of any part of these drawings without the written permission of the architect and where made, must bear his name. All prints to be returned to the architect.
 The contractor shall verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architect for adjustment.
 This drawing shall not be used for building purposes and counterchecked by:

THE CITY OF WINNIPEG

OFFICE ADDITION AND RENOVATIONS
 1155 PACIFIC AVENUE
 WINNIPEG, MANITOBA

FRIESEN TOKAR ARCHITECTS

MAIN FLOOR PLAN
 PART B - LIGHTING
E2.4

- NOTES
- ① HATCHED AREA * SURROUNDING SKYLIGHTS INDICATES AREA THAT THE CEILING SYSTEM WILL BE REMOVED. ELECTRICAL TO REMOVE AND REINSTALL LIGHTING, FIRE ALARM, PUBLIC ADDRESS, ETC. AS REQUIRED. RELOCATE ANY CONDUITS/WIRING AS NECESSARY TO ACCOMMODATE NEW ROOF OPENING FOR SKYLIGHTS.
 - ② EXISTING CIRCUITS IN THIS AREA ARE:
 - EA-1 (DOT SIGNS)
 - L1-B-9 (NORMAL LIGHTING)
 - EA-15 (EMERGENCY LIGHTING)
 - ③ OPEN AREA LIGHTING TO BE SWITCHED FROM HERE.
 - ④ LIGHTING LEVEL SENSOR AND OCCUPANCY SENSOR MOUNTED ON CEILING. PROGRAMMED TO TURN OFF ADJACENT FLUORESCENT LIGHTS.
 - ⑤ SKYLIGHT FIXTURES TO BE WIRED/CONTROLLED BY A LINE VOLTAGE DAY LIGHT SENSOR MOUNTED ON ADJACENT CEILING.
 - ⑥ CIRCUITS L3-3 AND EA-6 ARE EXISTING LIGHTING CIRCUITS FOR THIS AREA.

PART MAIN FLOOR PLAN - PART B LIGHTING
 SCALE 1/100

FOR CONTINUATION, REFER TO DRAWING E2.5

FOR CONTINUATION, REFER TO DRAWING E2.3