



ADDENDUM NO. 1 BID OPPORTUNITY NO. 187-2004

**SAND AND SALT STORAGE FACILITY AT 1539 WAVERLEY STREET,
YARD WORKS**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 3, 2004
BY: Andy Nagy
TELEPHONE NO. (204) 284-0580

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.

PART E – SPECIFICATIONS

Revise: Drawing 06

1) Distribution Panel "A" Schedule revise to read as follows:

Provide 3 - 20A, 1P circuit breakers in panel space 30, 32, 34.

Breakers to be labelled thus:

Circuit 30 – Bldg.Ltg. – North

Circuit 32 – Bldg.Ltg. – Centre

Circuit 34 – Bldg.Ltg. – South

2) The AS-100 Watt Stopper control switch to be shipped with the LP8 lighting control panel. AS-100 control switch to be installed by building installation contractor.