



ADDENDUM NO. 1 BID OPPORTUNITY NO. 493-2004

**SUPPLY AND INSTALLATION OF LIGHTING SYSTEM IN PAINT BOOTHS
AT 421 OSBORNE STREET**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 5, 2004
BY: Glenn F. Nakauchi /gfn
TELEPHONE NO. (204) 986-4970

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20040901

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART A – BID SUBMISSION

Replace: Form A: Bid and Form B: Prices with Form A(R1): Bid and Form B(R1): Prices provided in the file:

493-2004_Addendum_1-Part_A.pdf

PART B – BIDDING PROCEDURES

Revise: B2.1 The Submission Deadline is 12:00 noon Winnipeg time, November 10, 2004.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2 The major components of the Work are as follows:

Alternative A

The Work to be done under the Contract shall consist of the supply and installation of lighting system for Class 1, Division 1 locations in paint booths # 1, # 2, # 3, The major components of the Work are as follows:

- (a) Supply and installation of the explosion proof, dust ignition proof lighting fixtures for the paint booths lighting system, Class 1, Division 1 locations, including: Lighting fixtures, ballasts, lamps, brackets for installation fixtures on the wall;

The Contractor shall determine the amount of lighting fixtures according to the technological requirements for paint booths (see drawing E5);

- (b) Remove existing lighting system in paint booths # 1, # 2, # 3 (see drawing E1)
- (c) Modify ventilation system in comply with NFC, CEC, CSA as well as with any other Provincial or Municipal codes and regulations that apply for paint booths (see drawings E3, E4)
- (d) Supply and installation of Electrical Conduit and Conductor Cable;
- (e) Modify and upgrade to the existing Electrical Lighting Panel for new lighting system.

Alternative B

The Work to be done under the Contract shall consist of the supply and installation of lighting system Class 1, Division 1 locations in paint booths # 2, # 3. The major components of the Work are as follows:

- (a) Supply and installation of the explosion proof, dust ignition proof lighting fixtures for the paint booths lighting system, Class 1, Division 1 locations, including: Lighting fixtures, ballasts, lamps, brackets for installation fixtures on the wall;

The Contractor shall determine the amount of lighting fixtures according to the technological requirements for paint booths (see drawing E5);

- (b) Remove existing lighting system in paint booths # 2, # 3 (see drawing E1)
- (c) Replace all not working lighting fixtures in paint booth # 1 with old, CSA approved lighting fixtures from paint booths # 2 and # 3. (see drawing E1.1)
- (d) Modify ventilation system in comply with NFC, CEC, CSA as well as with any other Provincial or Municipal codes and regulations that apply for paint booths (see drawings E3, E4)
- (e) Supply and installation of Electrical Conduit and Conductor Cable;
- (f) Modify and upgrade to the existing Electrical Lighting Panel for new lighting system.