



FAN COIL SCHEDULE

SYMBOL	ROOM	MODEL	NO. RINGS	HEAT	COOL	UNIT	HP	REMARKS
FC-1	A-106	FC-106	1	0.7	1.2	LOW	1/20	FREE STANDING
FC-2	A-105	FC-105	1	0.7	1.2	LOW	1/20	FURRED IN
FC-3	A-104	FC-104	1	0.4	1.1	LOW	1/20	"
FC-4	A-103	FC-103	1	0.4	1.1	LOW	1/20	"
FC-5	A-102	FC-102	1	0.4	1.1	LOW	1/20	"
FC-6	A-101	FC-101	1	0.4	1.1	LOW	1/20	"
FC-7	A-100	FC-100	1	0.4	1.1	LOW	1/20	"
FC-8	A-99	FC-99	1	0.4	1.1	LOW	1/20	"
FC-9	A-98	FC-98	1	0.4	1.1	LOW	1/20	"
FC-10	A-97	FC-97	1	0.4	1.1	LOW	1/20	"
FC-11	A-96	FC-96	1	0.4	1.1	LOW	1/20	"
FC-12	A-95	FC-95	1	0.4	1.1	LOW	1/20	"
FC-13	A-94	FC-94	1	0.4	1.1	LOW	1/20	"
FC-14	A-93	FC-93	1	0.4	1.1	LOW	1/20	"
FC-15	A-92	FC-92	1	0.4	1.1	LOW	1/20	"
FC-16	A-91	FC-91	1	0.4	1.1	LOW	1/20	"
FC-17	A-90	FC-90	1	0.4	1.1	LOW	1/20	"
FC-18	A-89	FC-89	1	0.4	1.1	LOW	1/20	"
FC-19	A-88	FC-88	1	0.4	1.1	LOW	1/20	"
FC-20	A-87	FC-87	1	0.4	1.1	LOW	1/20	"
FC-21	A-86	FC-86	1	0.4	1.1	LOW	1/20	"
FC-22	A-85	FC-85	1	0.4	1.1	LOW	1/20	"
FC-23	A-84	FC-84	1	0.4	1.1	LOW	1/20	"
FC-24	A-83	FC-83	1	0.4	1.1	LOW	1/20	"
FC-25	A-82	FC-82	1	0.4	1.1	LOW	1/20	"
FC-26	A-81	FC-81	1	0.4	1.1	LOW	1/20	"
FC-27	A-80	FC-80	1	0.4	1.1	LOW	1/20	"
FC-28	A-79	FC-79	1	0.4	1.1	LOW	1/20	"
FC-29	A-78	FC-78	1	0.4	1.1	LOW	1/20	"
FC-30	A-77	FC-77	1	0.4	1.1	LOW	1/20	"
FC-31	A-76	FC-76	1	0.4	1.1	LOW	1/20	"
FC-32	A-75	FC-75	1	0.4	1.1	LOW	1/20	"
FC-33	A-74	FC-74	1	0.4	1.1	LOW	1/20	"
FC-34	A-73	FC-73	1	0.4	1.1	LOW	1/20	"
FC-35	A-72	FC-72	1	0.4	1.1	LOW	1/20	"
FC-36	A-71	FC-71	1	0.4	1.1	LOW	1/20	"
FC-37	A-70	FC-70	1	0.4	1.1	LOW	1/20	"
FC-38	A-69	FC-69	1	0.4	1.1	LOW	1/20	"
FC-39	A-68	FC-68	1	0.4	1.1	LOW	1/20	"
FC-40	A-67	FC-67	1	0.4	1.1	LOW	1/20	"
FC-41	A-66	FC-66	1	0.4	1.1	LOW	1/20	"
FC-42	A-65	FC-65	1	0.4	1.1	LOW	1/20	"
FC-43	A-64	FC-64	1	0.4	1.1	LOW	1/20	"
FC-44	A-63	FC-63	1	0.4	1.1	LOW	1/20	"
FC-45	A-62	FC-62	1	0.4	1.1	LOW	1/20	"
FC-46	A-61	FC-61	1	0.4	1.1	LOW	1/20	"
FC-47	A-60	FC-60	1	0.4	1.1	LOW	1/20	"
FC-48	A-59	FC-59	1	0.4	1.1	LOW	1/20	"
FC-49	A-58	FC-58	1	0.4	1.1	LOW	1/20	"
FC-50	A-57	FC-57	1	0.4	1.1	LOW	1/20	"
FC-51	A-56	FC-56	1	0.4	1.1	LOW	1/20	"
FC-52	A-55	FC-55	1	0.4	1.1	LOW	1/20	"
FC-53	A-54	FC-54	1	0.4	1.1	LOW	1/20	"
FC-54	A-53	FC-53	1	0.4	1.1	LOW	1/20	"
FC-55	A-52	FC-52	1	0.4	1.1	LOW	1/20	"
FC-56	A-51	FC-51	1	0.4	1.1	LOW	1/20	"
FC-57	A-50	FC-50	1	0.4	1.1	LOW	1/20	"
FC-58	A-49	FC-49	1	0.4	1.1	LOW	1/20	"
FC-59	A-48	FC-48	1	0.4	1.1	LOW	1/20	"
FC-60	A-47	FC-47	1	0.4	1.1	LOW	1/20	"
FC-61	A-46	FC-46	1	0.4	1.1	LOW	1/20	"
FC-62	A-45	FC-45	1	0.4	1.1	LOW	1/20	"
FC-63	A-44	FC-44	1	0.4	1.1	LOW	1/20	"
FC-64	A-43	FC-43	1	0.4	1.1	LOW	1/20	"
FC-65	A-42	FC-42	1	0.4	1.1	LOW	1/20	"
FC-66	A-41	FC-41	1	0.4	1.1	LOW	1/20	"
FC-67	A-40	FC-40	1	0.4	1.1	LOW	1/20	"
FC-68	A-39	FC-39	1	0.4	1.1	LOW	1/20	"
FC-69	A-38	FC-38	1	0.4	1.1	LOW	1/20	"
FC-70	A-37	FC-37	1	0.4	1.1	LOW	1/20	"
FC-71	A-36	FC-36	1	0.4	1.1	LOW	1/20	"
FC-72	A-35	FC-35	1	0.4	1.1	LOW	1/20	"
FC-73	A-34	FC-34	1	0.4	1.1	LOW	1/20	"
FC-74	A-33	FC-33	1	0.4	1.1	LOW	1/20	"
FC-75	A-32	FC-32	1	0.4	1.1	LOW	1/20	"
FC-76	A-31	FC-31	1	0.4	1.1	LOW	1/20	"
FC-77	A-30	FC-30	1	0.4	1.1	LOW	1/20	"
FC-78	A-29	FC-29	1	0.4	1.1	LOW	1/20	"
FC-79	A-28	FC-28	1	0.4	1.1	LOW	1/20	"
FC-80	A-27	FC-27	1	0.4	1.1	LOW	1/20	"
FC-81	A-26	FC-26	1	0.4	1.1	LOW	1/20	"
FC-82	A-25	FC-25	1	0.4	1.1	LOW	1/20	"
FC-83	A-24	FC-24	1	0.4	1.1	LOW	1/20	"
FC-84	A-23	FC-23	1	0.4	1.1	LOW	1/20	"
FC-85	A-22	FC-22	1	0.4	1.1	LOW	1/20	"
FC-86	A-21	FC-21	1	0.4	1.1	LOW	1/20	"
FC-87	A-20	FC-20	1	0.4	1.1	LOW	1/20	"
FC-88	A-19	FC-19	1	0.4	1.1	LOW	1/20	"
FC-89	A-18	FC-18	1	0.4	1.1	LOW	1/20	"
FC-90	A-17	FC-17	1	0.4	1.1	LOW	1/20	"
FC-91	A-16	FC-16	1	0.4	1.1	LOW	1/20	"
FC-92	A-15	FC-15	1	0.4	1.1	LOW	1/20	"
FC-93	A-14	FC-14	1	0.4	1.1	LOW	1/20	"
FC-94	A-13	FC-13	1	0.4	1.1	LOW	1/20	"
FC-95	A-12	FC-12	1	0.4	1.1	LOW	1/20	"
FC-96	A-11	FC-11	1	0.4	1.1	LOW	1/20	"
FC-97	A-10	FC-10	1	0.4	1.1	LOW	1/20	"
FC-98	A-9	FC-9	1	0.4	1.1	LOW	1/20	"
FC-99	A-8	FC-8	1	0.4	1.1	LOW	1/20	"
FC-100	A-7	FC-7	1	0.4	1.1	LOW	1/20	"

FAN SCHEDULE

FAN	MODEL	CFM	HP	RPM	S.P.	62 CURB	REMARKS
F-1	18-C-5R	1580	3/4	900	1/2	19 1/2	WASHROOM EXHAUST
F-2	18-C-5R	1664	3/4	1739	1	11"	KITCHEN EXHAUST (SEE DWG 2185-610)
F-3	84-V-2D	185	1/2	1500	1/2	11"	SENIOR'S CLUB W/R EXHAUST
F-4	84-V-2D	1270	1/4	1190	1/4		C.B.F. BLOW-THRU TYPE
F-5	SIZE 930	10000	2	969	3/8"		VARIABLE (SEE DWG 2185-611 FOR LOCATION)

NOTE: ALL CONDENSATE DRAIN PIPING TO BE 1/2" PLASTIC PIPE.

2185-609

19/1/68 2 0 FOR TENDER
22/1/67 1 0 FOR APPROVAL

DATE ISSUE REV. BY

DESCRIPTION

ISSUE OR REVISION

METROPOLITAN CORPORATION OF GREATER WINNIPEG
STREETS AND TRANSIT DIVISION

TRANSIT STORAGE AND SHOP FACILITIES

ADMINISTRATION BUILDING
HEATING, VENTILATING & AIR CONDITIONING - PLAN

CONSULTING PROFESSIONAL ENGINEERS
A. D. MARGISON AND ASSOCIATES LIMITED
155 LESLIE STREET, DON MILLS, ONTARIO

ARCHITECTS
Walsman Ross + Blankstein Coop Gillmor Hanna
10 DONALD STREET, WINNIPEG, MANITOBA

APPROVED: [Signature]
DEPUTY DIRECTOR OF STREETS AND TRANSIT

DRAWN BY: [Signature]
CHECKED BY: J.T.T.
FILE NO.:
SHEET NO.:

DATE: AUGUST '67
SCALE: AS SHOWN
DRAWING NO.: 2185-609
MECHANICAL