

APPENDIX A
2005 TPR LOCATIONS AND DESIGN CONDITIONS

**APPENDIX A
 2005 TPR LOCATIONS AND DESIGN CONDITIONS**

Repair Location				Removal of Intruding Sewer Services			Solid Debris Cutting			Pipe Condition			CIPP Internal Point Repair Details					
Street Name	Sewer ID	Sewer Length(m)	Drawing Number	Reference MH ID	Direction	Location	Reference MH ID	Direction	Location	Ø (mm)	Ovality (%)	Design* Condition	Reference MH ID	Direction	Start (m)	End (m)	Length (m)	Sewer Services
Bannerman Ave	18176	100.8	05710							375	5	FD	18175	DS	1.0	7.3	6.3	0
Beach Ave	20874	106.8	05711							300	3	PD	20867	US	0.6	1.6	1.0	0
Burnell St	8839	78.8	05712							375	3	PD	8819	US	0.6	2.0	1.4	0
Ducharme Ave	59679	42.8	05713							250	2	FD	95236	DS	31.9	33.5	1.6	0
Eaton St	21106	38.5	05714							300	10	PD	21107	DS	10.0	11.3	1.3	0
Elizabeth Rd	24910	98.0	05715							300	2	FD	24911	DS	94.7	96.6	1.9	0
Grant Ave	21770	42.2	05716							300	6	PD	21772	US	0.6	1.8	1.2	0
Keewatin St	23268	46.8	05717							300	3	FD	23269	DS	0.8	3.8	3.0	0
Kenaston Blvd	21151	97.6	05718							450	6	PD	21150	DS	9.5	10.5	1.0	1
Kenaston Blvd	22685	87.3	05719	22684	DS	21.5 (11)	573	US	14.7 (02), 31.1 (07-05)	300	3	PD	22684	DS	20.8	22.8	2.0	1
										300	2	PD	573	US	13.2	16.0	2.8	1
Kings Dr	56412	116.9	05720				92229	DS	21.1, 26.5, 32.7, 34.3, 46.6, 101.8 (07-05)	200	2	FD	92229	DS	41.5	45.3	3.8	1
Lanark Ave	22	95.4	05721	578	DS	9.5 (01)	578	DS	80.4 (07-05)	450	9	PD	578	DS	0.6	9.5	8.9	0
Lindsay St	4	12.7	05722							450	3	FD	627	DS	0.6	1.6	1.0	0
Lindsay St	68	96.8	05723							450	6	PD	585	DS	43.6	47.5	3.9	2
Lindsay St	22555	88.1	05724				22554	DS	31.1 (12-03), 31.7 (07-12)	300	6	PD	22554	DS	30.8	33.8	3.0	2
													22554	DS	0.6-11.7 Renewed Since Televised			
Martin Ave	20945	100.2	05725							450	2	FD	20944	DS	0.6	1.6	1.0	0
McCalman Ave	21067	110.1	05726				20896	US	9.9 (01)	450	8	FD	20166	DS	86.0	93.4	7.4	1
Montrose St	21903	94.6	05727							300	5	FD	21905	US	0.6	2.8	2.2	0
Niagara St	22023	85.6	05728	22022	DS	72.3 (12)				300	7	FD	22024	US	11.2	13.7	2.5	2
Oak St	117	93.7	05729				601	DS	9.3, 9.7 (02-04), 9.9 (11)	375	10	PD	601	DS	17.0	18.0	1.0	0
Parker Ave	18632	85.0	05730				18631	DS	13 (01)	600	6	FD	18633	US	1.8	3.2	1.4	1
							18633	US	26.9-31.7 (03-04)									
Smart St	8913	82.4	05731				8912	DS	10.5 (10), 60.6, 63.2 (03+09)	300	6	FD	8912	DS	11.5	14.0	2.5	0
										300	9	PD	8912	DS	59.5	65.5	6.0	1
Strathcona St	23824	99.9	05732				23823	DS	39.5 (07-09), 40.1 (09)	375	4	PD	23823	DS	38.4	41.2	2.8	2
Waterloo St	22106	91.9	05733	22105	DS	15.3, 27.2 (11)	22105	DS	2.1 (02), 86.5 (01-03), 87.4 (09-12)	450	3	PD	22105	DS	25.3	28.3	3.0	4
										450	6	FD	22105	DS	83.3	91.3	8.0	2
													22105	DS	93.1-96.4 Renewed Since Televised			
Waverley St	22129	96.9	05734	21912	DS	69.4 (12)	21912	DS	93.8 (04+07), 94.3 (02)	300	6	PD	21912	DS	65.8	72.5	6.7	1
Wellington Cr	21385	30.9	05735							300	5	PD	21387	US	0.6	2.1	1.5	0

* FD - Fully Deteriorated
 * PD - Partially Deteriorated