


THIRD FLOOR POWER AND LIGHTING PLAN (AREA 2) 1:100

NOTES:

- 1. ALL 120V AND 208V LOADS ARE FED FROM LP-H31
- EMERGENCY LIGHTING EM-X-1 ARE FED FROM BATERY PACK EM-X.
- 3. MOUNT TYPE A LUMINAIRE AT 3.0m AVOBE THE FLOOR
- 4. SEE DWG WB-E0401 FOR TYPE A FIXTURE MOUNTING
- SEE DWG WB-E402 DET 2 FOR TYPE J FIXTURE MOUNTING DETAILS



==APEGN	B.M. ELEV.		Frederickson Cooper ARCHITECTS		Earth Tech A Tyco International Ltd. Company	ENGINEER'S SEAL ORIGINAL SIGNED BY	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
Certificate of Authorization			DESIGNED BY	LL	CHECKED ND	L.D. LLÉWELLYN	WATER TREATMENT PLANT	CITY FILE NUMBER
CH2M HILL Canada Ltd.			DRAWN BY	TL	APPROVED AHL	2006/03/29	FILTRATION MECHANICAL AND ELECTRICAL	SHEET OF
No. 1441 Expiry: April 30, 2007	01 742-2005 ADDENDUM 3	06/05/19 LL 06/05/05 LL 06/03/29 LL	SCALE:	1:100	RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO.	ELECTRICAL FILTRATION AREA 2	CITY DRAWING NUMBER 1-0601F-A-E0136-001-02D
	NO. REVISIONS	DATE BY	DATE	2005/07/13	DATE 2006/03/29	WF-E0136	THIRD FLOOR POWER AND LIGHTING PLAN	1 00011 A E0100 001 02D