




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-PSU-O310A-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	PSU-O310A	Power Meter: Ozone Generator 1	
0	C-PSU-O320A-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	PSU-O320A	Power Meter: Ozone Generator 2	
0	C-PSU-O330A-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	PSU-O330A	Power Meter: Ozone Generator 3	
0	C-WTPAPRTR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPAPRTR01	Router/Gateway Network Cable	
0	C-WTPAPRTR02-C01	4-Pair #24 AWG - Cat 5E		CP-D01A DBPS Communication Panel	WTPAPRTR02	Existing DBPS PLC Network Switch Network Cable	Not in Contract 742-2005.
0	C-WTPSVES01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Control Network Cable	
0	C-WTPSVES01-C02	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Monitoring Network Cable	
0	C-WTPSVHIS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVHIS01	Primary Historical Server Network Cable	
0	C-WTPSVHIS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVHIS02	Standby Historical Server Network Cable	
0	C-WTPSVRVS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVRVS01	Primary Real Time Server Plant Control Network Cable	
0	C-WTPSVRVS01-C02	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVRVS01	Primary Real Time Server Plant Monitoring Network Cable	
0	C-WTPSVRVS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Control Network Cable	
0	C-WTPSVRVS02-C02	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Monitoring Network Cable	
0	C-WTPWSC11 01-C01	4-Pair #24 AWG - Cat 5E		CP-C11A Polymer Communication Panel	WTPWSC11 01	Local Operator Workstation at CP-C11 Network Cable	
0	C-WTPWSCR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR01	Operator Workstation 01 Network Cable	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
			DESIGNED BY SWT CHECKED BY SWT		ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29				WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL
			DRAWN BY SWT APPROVED BY AHL				CONSULTANT DRAWING NO. WH-A0607		SHEET 7 OF 11
			SCALE: NTS RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST				CITY DRAWING NUMBER 1-0601H-K-A0607-001-01B
			NO. REVISIONS DATE BY DATE 2006/03/29 DATE 2006/03/29						

Thursday, May 25, 2006