




CP-J11A	Sodium Hypochlorite Communication Panel				
Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
Primary Sodium Hypochlorite PLC	Switch 1	01	RJ-45	C-CP-J11-C01	4-Pair #24 AWG - Cat 5E TO CP-J11
Standby Sodium Hypochlorite PLC		02	RJ-45	C-CP-J11-C02	4-Pair #24 AWG - Cat 5E TO CP-J11
Spare		03			
Spare		04			
Spare		05			
Spare		06			
Plant Control Network Receive	PP1: 01	07-Rx			
Plant Control Network Transmit	PP1: 02	07-Tx			
Plant Control Network Receive	PP1: 14	08-Rx			
Plant Control Network Transmit	PP1: 13	08-Tx			
	Switch 2	01	RJ-45	C-WTPWSJ11 01-C01	4-Pair #24 AWG - Cat 5E TO WTPWSJ11 01
Spare		02			
Spare		03			
Spare		04			
Spare		05			
Spare		06			
Plant Monitoring Network Receive	PP1: 05	07-Rx			
Plant Monitoring Network Transmit	PP1: 06	07-Tx			
Plant Monitoring Network Receive	PP1: 18	08-Rx			
Plant Monitoring Network Transmit	PP1: 17	08-Tx			

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0519	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
				DESIGNED BY	SWT				CHECKED BY	SWT
				DRAWN BY	SWT		APPROVED BY	AHL	SHEET 19 OF 63	CITY DRAWING NUMBER 1-0601H-J-A0519-001-00B
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:			
				0	ISSUED FOR TENDER		06/03/29	SWT		
			NO.	REVISIONS	DATE	BY	DATE	2006/03/29		



Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2006.

Monday, April 03, 2006