




CP-P32	DAF Basins 5-8 Control Panel		Jumper or Internal Cable	Conductor #	Cable	Cable Information
Comments						
			Switch 1			
	RJ-45 To PLC		01			
	RJ-45 To PLC		02			
			03	RJ-45	C-CP-P32-C01	4-Pair #24 AWG - Cat 5E TO CP-P31A
			04	RJ-45	C-LCP-P12A-C01	4-Pair #24 AWG - Cat 5E TO LCP-P12A
			05	RJ-45	C-LCP-P38-C01	4-Pair #24 AWG - Cat 5E TO LCP-P38
			06	RJ-45	C-LCP-P37-C01	4-Pair #24 AWG - Cat 5E TO LCP-P37
			07	RJ-45	C-LCP-P36-C01	4-Pair #24 AWG - Cat 5E TO LCP-P36
			08	RJ-45	C-LCP-P35-C01	4-Pair #24 AWG - Cat 5E TO LCP-P35
	RJ-45 To Local HMI		09			
Spare			10			
Spare			11			
Spare			12			
Spare			13			
Spare			14			
Spare			15			
Spare			16			

NOTES: 1. Panel Supplied by the City.	B.M. ELEV.			 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
				DESIGNED BY	SWT				CHECKED BY	SWT
				DRAWN BY	SWT		APPROVED BY	AHL	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	SHEET 28 OF 63
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI	CITY DRAWING NUMBER	
 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.			0	ISSUED FOR TENDER	06/03/29	SWT	CONSULTANT DRAWING NO.	WH-A0528	1-0601H-J-A0528-001-00B	
			NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29

Monday, April 03, 2006