




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-JY-H951A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951A	SWGR 1A Protection Relay Comm. Cable	
0	C-JY-H951B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951B	SWGR 1B Protection Relay Comm. Cable	
0	C-JY-H952A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952A	MCC 1A Protection Relay Comm. Cable	
0	C-JY-H952B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H952B	MCC 1B Protection Relay Comm. Cable	
0	C-JY-H953A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953A	MCC 2A Protection Relay Comm. Cable	
0	C-JY-H953B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H953B	MCC 2B Protection Relay Comm. Cable	
0	C-JY-H954A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954A	MCC 3A Protection Relay Comm. Cable	
0	C-JY-H954B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H954B	MCC 3B Protection Relay Comm. Cable	
0	C-JY-H955A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955A	Main Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	
0	C-JY-H955B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H955B	Main Building 4160/600 VAC XFMR B Protection Relay Comm. Cable	
0	C-JY-H961A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H961A	SWGR 2A Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H961B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H961B	SWGR 2B Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H962A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H962A	MCC 4A Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H962B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H962B	MCC 4B Protection Relay Comm. Cable	Not in Contract 742-2005.
0	C-JY-H965A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JY-H965A	Bulk Chemical Building 4160/600 VAC XFMR A Protection Relay Comm. Cable	Not in Contract 742-2005.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
			DESIGNED BY: SWT		CHECKED BY: SWT			
			DRAWN BY: SWT		APPROVED BY: AHL		WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	
			SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI			
	0 ISSUED FOR TENDER		06/03/29	SWT	CONSULTANT DRAWING NO. WH-A0604		SHEET 4 OF 9	
NO. REVISIONS		DATE	BY	DATE 2006/03/29	DATE 2006/03/29	AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		
						CITY DRAWING NUMBER 1-0601H-K-A0604-001-00B		

Monday, April 03, 2006