



## 196-2006 ADDENDUM 1

SUPPLY AND DELIVERY OF AERATION EQUIPMENT FOR THE NORTH  
END WATER POLLUTION CONTROL CENTRE CENTRATE NITROGEN  
REMOVAL FACILITY

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: April 28, 2006  
BY: Eric Hutchison P.Eng  
TELEPHONE NO. (204) 477-5381

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050506

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

Section 11531 Clause 2.3.2.1

REVISE TO READ:

“Maximum: 252 Nm<sup>3</sup>/minute per sequencing batch reactor when water depth (from tank floor) is 6.3 m or less.”