



- ### DRAWING NOTES
- 1 DISCONNECT EXISTING EXHAUST FAN MOTORS S-638 AND S-639 AND MAKE READY FOR REMOVAL. REMOVE EXISTING CABLES.
 - 2 OVERHEAD DOOR OPENER AND CONTROL PROVIDED AND INSTALLED BY GENERAL CONTRACTOR. CONNECTED BY ELECTRICAL CONTRACTOR.
 - 3 CABLES INSTALLED IN WALKWAY TO BIOREACTOR ELECTRICAL ROOM. REFER TO MOTOR CONTROL SCHEDULE FOR POWER CABLE SIZES.
 - 4 CONDUCTOR FROM S770-P-VFD TO PUMP S770-P CONTROLS ON ROOF OF BIOREACTOR.
 - 5 CONDUCTOR FROM S771-P-VFD TO PUMP S771-P CONTROLS ON ROOF OF BIOREACTOR.
 - 6 INSTALL CORED OPENING NEAR TOP OF TANK (ABOVE HIGH LEVEL) TO ALLOW FOR WATERPROOF SEAL FOR CABLE FROM VFD TO DISCONNECT ON TANK ROOF ADJACENT TO ACCESS HATCH. PROVIDE ROXTEC RS WEATHER TIGHT SEALS SIZED TO SUIT CABLES.
 - 7 PROVIDE CONNECTIONS TO NEW EXHAUST FAN MOTORS S638 AND S639, VFD'S AND MCC-1SB AND MCC-2SB IN BIOREACTOR ELECTRICAL ROOM.
 - 8 WIRE AND CONNECT NEW SUMP PUMPS S768 AND S769 AND ASSOCIATED CONTROLS.
 - 9 SUMP PUMP S768 AND S769 CONTROL CABINET c/w ALTERNATOR, STARTER & CONTROLS SUPPLIED BY DIV. 15.
 - 10 MOTORIZED DAMPERS SUPPLIED AND INSTALLED BY DIVISION 15. CONNECTED BY DIVISION 16. REFER TO MECHANICAL DRAWINGS FOR DAMPER LOCATIONS.

- ### GENERAL NOTES
1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
 2. USE PVC JACKETED HI TECH CABLE FOR ALL POWER WIRING.
 3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RIGID ALUMINUM CONDUIT.
 4. ALL CONDUIT TO BE 21mmø MINIMUM UNLESS OTHERWISE NOTED.

BIOREACTORS 1 & 2 - LOWER LEVEL POWER PLAN
SCALE: 1:100



B.M. ELEV.				
01	21-2006 ADDENDUM 3	06/05/19	ERC	
00	ISSUED FOR TENDER	06/04/26	ERC	
NO.	REVISIONS	DATE	BY	DATE

EarthTech
A Tyco International Ltd. Company

DESIGNED BY: GSN	CHECKED BY: PS
DRAWN BY: ERC	APPROVED BY: JEH
HOR. SCALE: NTS	RELEASED FOR CONSTRUCTION BY: J. VEILLEUX
VERTICAL SCALE:	DATE: 2005/11/22
	DATE: 2006/04/26

ENGINEER'S SEAL

ORIGINAL SIGNED BY
P. STRYK
2006/04/26

CONSULTANT DRAWING NO.
SE1.01

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WEWPC
BIOLOGICAL NUTRIENT REMOVAL UPGRADE
CONTRACT 3

ELECTRICAL
AREA S - BIOREACTORS
LOWER LEVEL POWER PLAN

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER