



LEGEND
 +-----+ PIPE WORK TO BE REMOVED

WAS PUMP 1
 EQUIP. NO.: S-810-WAP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 DRIVE: VARIABLE SPEED
 CAPACITY: 15 L/s
 HEAD: 5 m
 POWER: 5 kW

WAS PUMP 2
 EQUIP. NO.: S-820-WAP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 DRIVE: VARIABLE SPEED
 CAPACITY: 15 L/s
 HEAD: 5 m
 POWER: 5 kW



| | | | |
|-----------------|-------------------|-------------------------------|-------------|
| B.M. ELEV. | | | |
| DESIGNED BY | CGL/EVS | CHECKED BY | KM/ST |
| DRAWN BY | LAE/PPL | APPROVED BY | JEH |
| HOR. SCALE: | NONE | RELEASED FOR CONSTRUCTION BY: | J. VEILLEUX |
| VERTICAL SCALE: | | DATE | 2005/07/06 |
| NO. | ISSUED FOR TENDER | DATE | 06/04/26 |
| NO. | REVISIONS | DATE | BY |



ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 S.W. TORMEY
 2006/04/26
 CONSULTANT DRAWING NO.
 LI2.05

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WEWPCC
 BIOLOGICAL NUTRIENT REMOVAL UPGRADE
 CONTRACT 3
 PROCESS
 AREA S - BIOREACTORS
 WASTE ACTIVATED SLUDGE SYSTEM - P&ID

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER