



**DAF POLYMER SYSTEM**

EQUIP. NO.: T-130-POL  
 SPEC: 11771  
 TYPE: DRY  
 POLYMER DOSE RATE: 14.6 kg/d  
 SOLUTION CONCENTRATION: 0.5 %

**DAF POLYMER METERING PUMP 1**

EQUIP. NO.: T-131-POF  
 SPEC: 11365  
 TYPE: PROGRESSIVE CAVITY  
 CAPACITY: 120 L/hr  
 HEAD: 10 m  
 POWER: 0.5 hp

**DAF POLYMER METERING PUMP 2**

EQUIP. NO.: T-132-POF  
 SPEC: 11365  
 TYPE: PROGRESSIVE CAVITY  
 CAPACITY: 120 L/hr  
 HEAD: 10 m  
 POWER: 0.5 hp

**NOTES:**

- LEVEL SWITCH T-131-LSLL NOT PART OF DRY POLYMER PRE-ENGINEERED SYSTEM PACKAGE.



|                       |            |                               |             |
|-----------------------|------------|-------------------------------|-------------|
| B.M. ELEV.            |            |                               |             |
| DESIGNED BY           | EM/EVS     | CHECKED BY                    | KM/ST       |
| DRAWN BY              | PJY/PPL    | APPROVED BY                   | JEH         |
| HOR. SCALE:           | NONE       | RELEASED FOR CONSTRUCTION BY: | J. VEILLEUX |
| VERTICAL SCALE:       |            |                               |             |
| NO. ISSUED FOR TENDER | 06/04/26   | CD                            |             |
| NO. REVISIONS         | DATE       | BY                            | DATE        |
|                       | 2005/07/06 |                               | 2006/04/26  |



ENGINEER'S SEAL

ORIGINAL SIGNED BY

S.W. TORMEY

2006/04/26

CONSULTANT DRAWING NO.

LI4.01



**WEWPCC**  
 BIOLOGICAL NUTRIENT REMOVAL UPGRADE  
 CONTRACT 3

CITY FILE NUMBER

SHEET OF

CITY DRAWING NUMBER

PROCESS  
 AREA T - DAF THICKENER BUILDING  
 DAF POLYMER SYSTEM - P&ID