



MAIN FLOOR – LIGHTING & SYSTEMS PLAN
SCALE: 1:50

- DRAWING NOTES**
- COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
 - 3/C#12 TECK TO PANEL HEAA IN HEADWORKS BUILDING ELECTRICAL ROOM.
 - 2/C#12 TECK TO PANEL TAA IN ELECTRICAL ROOM.
- GENERAL NOTES**
- COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
 - USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
 - WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RIGID ALUMINUM CONDUIT.
 - ALL CONDUIT TO BE 21mmØ MINIMUM UNLESS OTHERWISE NOTED.



<p>EarthTech A Tyco International Ltd. Company</p>		ENGINEER'S SEAL ORIGINAL SIGNED BY P. STRYK 2006/04/26 CONSULTANT DRAWING NO. TE1.01	
DESIGNED BY	GSN	CHECKED BY	PS
DRAWN BY	ERC	APPROVED BY	JEH
HOR. SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX
VERTICAL SCALE:		DATE	2005/11/22
DATE	2005/11/22	DATE	2006/04/26

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WEWPCC
 BIOLOGICAL NUTRIENT REMOVAL UPGRADE
 CONTRACT 3

ELECTRICAL
 AREA T – DAF THICKENER BUILDING
 MAIN FLOOR LIGHTING AND SYSTEMS PLAN

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER