



1
E3.03
CENTRATE WAS TIE-IN LOCATION SAMPLE PUMP AND FRIDGE. REFER TO DETAIL

2-2/C#12 FROM SECONDARY ELECTRICAL ROOM TO NEW RECEPTACLES FOR SAMPLING EQUIPMENT

APPROXIMATE LOCATION OF SECOND FLOOR SLUDGE DEWATERING ELECTRICAL ROOM. PROVIDE NEW:
ONE (1) 1Ø, 208V, 0.5HP MOTOR STARTER.
ONE (1) 15A-2P BREAKER AND TWO (2) 15A-1P BREAKERS IN EXISTING PANELS FOR NEW SAMPLING EQUIPMENT.

1
E3.03
CENTRATE AND FLUSHING WATER TIE-IN LOCATION SAMPLE PUMP, SAMPLER AND FRIDGE. REFER TO DETAIL

- SODA ASH FACILITY
- METHANOL STORAGE TANKS
- NITROGEN REMOVAL FACILITY
- FACILITY TRANSFORMERS
- SURFACE DUCT BANK MARKERS TYPICAL

SITE PLAN
SCALE: N.T.S.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION				
			DESIGNED BY PS		CHECKED BY GSN	ORIGINAL SIGNED BY P. STRYK		
			DRAWN BY CPG		APPROVED BY JEH	2005/05/15		
			SCALE: NTS		RELEASED FOR CONSTRUCTION BY: K. MARTENS	CONSULTANT DRAWING NO. E1.02		
	00 ISSUED FOR TENDER 06/05/15 CPG	NO. REVISIONS	DATE 2006/02/23	DATE 2006/05/23	NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY ELECTRICAL OVERALL SITE PLAN	CITY FILE NUMBER	SHEET OF	CITY DRAWING NUMBER